

Questions & Answers from Mandatory LMR Tower Build RFP Meeting

Durham Town Hall
8 Newmarket Road
Durham, NH 03824

February 4, 2020

- Winning Bidder to provide engineered drawings, structural analysis, and all Trade permits.
 - NB+C will handle zoning due diligence and regulatory compliance requirements.
1. **What type of fuel to be used for generator?** Propane. RFP indicates the bidder to provide only the concrete generator pad.
 2. **What's the trench utility construction per Eversource requirements?** This question will be answered under separate cover.
 3. **Per FAA regulations, does the tower need to be painted/marked?** This will be *flushed out* during regulatory compliance.
 4. **Is the soil resistivity testing available?** No, to be conducted in the Spring, 2020. For the bid, presume "reasonably conductive soils." Refer to GeoTech provided.
 5. **Does the existing fence need to be expanded to accompany tower site?** Yes