



ENGINEERING, P.C.
CIVIL • STRUCTURAL • ENVIRONMENTAL

5 Railroad Street • P.O. Box 359
Newmarket, NH 03857
Phone: (603) 659-4979
Email: mjs@mjs-engineering.com

TEST PIT LOGS

PROPERTY OWNER: Sirles Revocable Trust
PROPERTY ADDRESS: 12 Mathes Cove Road, Durham, NH
LOCATION: Tax Map #12 Lot #9-12

DATE TEST PITS PERFORMED: 06/08/17
TEST PITS LOGGED BY: Michael J. Sievert Designer # 773
TEST PITS WITNESSED BY: Audrey Cline, Building Inspector
TEST PITS DUG BY: Coulstring Construction, LLC-small backhoe

Test Pit #8

0-6" Top Soil
6-19" Fine sandy loam, granular, loose (5yr 5/4)

Refusal @ 19"

Test Pit #9

2-0" Forest Mat
0-18" Fine sandy loam, granular, loose (5yr 4/4)
18-36" Loamy find sand, granular, loose (10yr 4/6)

SHWT @ 26"
Refusal @ 36"