



TOWN OF DURHAM
8 NEWMARKET RD
DURHAM, NH 03824-2898

AUDREY CLINE
Zoning Administrator
Code Enforcement Officer
Health Officer

TEL: (603) 868-8064
acline@ci.durham.nh.us

Decision or Order of the Building Inspector/Code Enforcement Officer

Applicant: Rockingham Properties 1, LTD, PO Box 423, Belmont MA 02478 Road, Durham

Map & Lot: As declared on Site Plan Sheet C-2.0 referenced below

Date of order: August 23, 2017


Decision or Order of the Building Inspector/Code Enforcement Officer:

- 1) ARTICLE XXI
OFF-STREET PARKING AND LOADING
175-111. General Requirements.
 - A. Standard vehicle parking space size and aisle width. For 90 degree parking a standard vehicle parking space shall measure nine by eighteen (9 x 18) feet, and the **aisle width shall be twenty-two feet.**

- 2) ARTICLE XXI
OFF-STREET PARKING AND LOADING
175-111. General Requirements.
 - D. No driveway in the front yard setback shall be **wider than twenty-two (22) feet**, except as permitted under 175-117 C 3.

Deadline for application to the Zoning Board: September 23, 2017

By Durham's Building Inspector/Code Enforcement Officer:



Audrey Cline CEO